



DWA Set of Rules

Standard DWA-A 216E

Energy Check and Energy Analysis –
Instruments to Optimise the Energy Usage of Wastewater Systems

December 2015

Energiecheck und Energieanalyse –
Instrumente zur Energieoptimierung von Abwasseranlagen
Dezember 2015

PREVIEW

PREVIEW

DWA Set of Rules

Standard DWA-A 216E

Energy Check and Energy Analysis
Instruments to Optimise the Energy Usage of Wastewater Systems

December 2015

Energiecheck und Energieanalyse –
Instrumente zur Energieoptimierung von Abwasseranlagen
Dezember 2015

PREVIEW

The German Association for Water, Wastewater and Waste (DWA) is strongly committed to the development of secure and sustainable water and waste management. As a politically and economically independent organisation it is professionally active in the field of water management, wastewater, waste and soil protection.

In Europe DWA is the association with the largest number of members within this field. Therefore it takes on a unique position in connection with professional competence regarding standardisation, professional training and information. The approximately 14,000 members represent specialists and executives from municipalities, universities, engineering offices, authorities and companies.

Imprint

Publisher and marketing:

German Association for
Water, Wastewater and Waste (DWA)
Theodor-Heuss-Allee 17
53773 Hennef, Germany
Tel.: +49 2242 872-333
Fax: +49 2242 872-100
E-Mail: info@dwa.de
Internet: www.dwa.de

Translation:

Fachübersetzungen Lanz, Ahlen

Print:

druckhaus köthen GmbH & Co KG

ISBN:

978-3-88721-570-5 (Print)
978-3-88721-571-2 (E-Book)

Printed on 100 % recycled paper

© Deutsche Vereinigung für Wasserwirtschaft, Abwasser und Abfall e. V. (DWA), Hennef December 2017
German Association for Water, Wastewater and Waste

All rights, in particular those of translation into other languages, are reserved. No part of this Standard may be reproduced in any form – by photocopy, digitalisation or any other process – or transferred into a language usable in machines, in particular data processing machines, without the written approval of the publisher.

Editor's Note on the English Translation

The energetic optimisation of wastewater systems has been a central issue in Germany since the 1990s. At that time, among other things, the handbook "Energie in Kläranlagen – Handbuch" (MURL 1999) was published by the state of North Rhine-Westphalia. This handbook described the procedure for the preparation of energy checks and energy analysis for wastewater treatment plants for the first time. In Germany, this was followed by a more than a decade-long specialist discussion on how the energetic situation of municipal wastewater treatment plants should be appropriately assessed. The central result of this dispute is the insight that the energetic situation of a specific wastewater system cannot be appropriately assessed either through the comparison with fixed key indicators (e.g. the annual electricity consumption per connected total number of inhabitants and population equivalents) or on the basis of statistical average values of other wastewater systems, as the individual boundary conditions of the wastewater systems vary too much.

Against this background, a new procedure was established in 2015 with the Standard DWA-A 216 "Energy Check and Energy Analysis – Instruments to Optimise the Energy Usage of Wastewater Systems". According to this, the assessment of the energetic situation of a wastewater treatment plant is based on the comparison of the as-is status with the **plant-specific ideal value which the considered wastewater treatment plant is able to achieve**. Only this comprehensive approach in the context of an energy analysis makes it possible to appropriately capture the actual potentials for the energetic optimisation at the respective plant and to develop meaningful measures to improve the energetic situation. For an initial orienting assessment of the energetic situation of a wastewater treatment system, the Standard DWA-A 216 offers the additional instrument of the energy check.

The present English version of the Standard DWA-A 216E is an unaltered translation of the original German text and therefore also contains information that applies specifically to the situation in Germany.

The technical concept of the Standard DWA-A 216 is also described in the "Guidelines – Energy Efficiency in Water and Wastewater Utilities" (11/2015), which were developed within the framework of a project funded by the Deutsche Gesellschaft für Internationale Zusammenarbeit (GIZ) and published by the Arab Countries Water Utilities Association (ACWUA 2015).

Foreword

Fully functional wastewater systems are a basic requirement for intact water bodies and represent indispensable infrastructure facilities for a modern state. Energy is required by urban drainage systems to fulfil this important task. Wastewater treatment plants are among the main power consuming units of municipalities. There are about 10.000 wastewater treatment plants in Germany and their total energy consumption is in a magnitude of 4.200 gigawatt-hours (GWh) per year (DWA 2010). This is roughly equivalent to the energy demand of 900.000 four-person households or – expressed in CO₂ equivalents – an emission in the order of 2,36¹⁾ million tonnes per year (with 562 g CO_{2,e}/kWh according to UBA (2014)). The energy demand of wastewater treatment plants not only depends on the cleaning process and the cleaning objective but also on the local boundary conditions and energy efficiency achieved.

The demand for energy is rising worldwide, the finite nature of fossil resources, increasing energy costs and concern about impact on the climate demands a major change in the energy supply and energy use – this also applies to the field of urban drainage.

Due to the local concentration of energy intensive plant components and the simultaneous generation of a source of energy and the generation of electrical and thermal energy, urban drainage offers numerous possibilities for reducing energy demand and increasing energy efficiency.

In doing so, these efforts to improve the energy efficiency should not contravene the primary purpose of urban drainage, that is discharge and treatment of wastewater with the objective of protecting the waterbodies.

Energy analysis, investigations by the German Federal Environmental Agency (HABERKERN et al. 2008) and the DWA (DWA 2010) as well as the “Benchmarking Abwasser NRW (KOMMUNAL- UND ABWASSERBERATUNG NRW 2011)) clearly show the potentials to increase the energy efficiency of wastewater systems. Optimisation of energy efficiency not only offers both energy-related and economic benefits but often goes hand in hand with an improvement in the cleaning performance of the wastewater systems and thus improves water pollution control.

Considering the complexity of the processes within the wastewater disposal, a systematic approach and extensive expertise with regard to the energy optimisation of wastewater systems is essential. So far there is no consistent and uniform methodology for evaluation of the energy efficiency of wastewater systems throughout Germany.

The present Standard introduces an energy check and energy analysis as tools for the energy optimisation of wastewater systems and covers the requirements stipulated for using these methods.

For reasons of a concise and reader friendly text in this Standard generally the male form is set for personalised professional job titles and function designations. All information applies to both genders.

Former editions

No former document

1) Editor’s note: In Standard DWA-A 216E a comma is used as decimal marker.

Authors

This Standard was elaborated by the DWA Working Group KEK-10.3 "Energy analysis of wastewater treatment plants" within the DWA Technical Committee KEK-10 "Energy in Water and Waste Management", which consists of the following members:

FRICKE, Klaus	Dipl.-Ing., Berlin
HABERKERN, Bernd	Dipl.-Ing., Darmstadt
JAGEMANN, Peter	Dipl.-Ing., Essen
KASTE, Andrea	Dipl.-Ing., Düsseldorf (Speaker)
KOBEL, Beat	Dipl.-Ing., Bern
KOENEN, Stefan	Dipl.-Ing., Bochum
MITSDOERFFER, Ralf	Dr.-Ing., München
RIßE, Henry	Dr.-Ing., Aachen
SCHMELLENKAMP, Peter	Dipl.-Ing., Bremen
THEILEN, Ulf	Prof. Dr.-Ing., Gießen
THÖLE, Dieter	Dr.-Ing., Ruhrverband, Essen (Deputy Speaker)

The DWA Technical Committee KEK-10 "Energy in Water and Waste Management" consists of the following members:

SCHRÖDER, Markus	Prof. Dr.-Ing., Aachen (Chairman)
Brandenburg, Heinz	Dipl.-Ing., Köln
ERBE, Volker	Dr.-Ing., Wuppertal
FRICKE, Klaus	Dipl.-Ing., Berlin
GREDIGK-HOFFMANN, Sylvia	Dipl.-Ing., Aachen
GRÜN, Emanuel	Dr.-Ing., Essen
HABERKERN, Bernd	Dipl.-Ing., Darmstadt
HANSEN, Joachim	Prof. Dr.-Ing., Luxemburg
HEß, Julian	RA, Köln
JAGEMANN, Peter	Dipl.-Ing., Essen
KASTE, Andrea	Dipl.-Ing., Düsseldorf
KOBEL, Beat	Dipl.-Ing., Bern
MAURER, Peter	Dipl.-Ing., Stuttgart
MÜLLER-SCHAPER, Johannes	Dr.-Ing., Hannover
MÜLLER, Ernst A.	Dipl.-Geogr., Schaffhausen
ROBECKE, Ulrich	Dr.-Ing., Münster
SCHÄFER, Arnold	Dipl.-Ing., Hamburg
SEIBERT-ERLING, Gerhard	Dr.-Ing., Frechen
THÖLE, Dieter	Dr.-Ing., Essen
WEILBEER, Julia	Dr.-Ing., Hetlingen

Responsible in the DWA Head Office:

REIFENSTUHL, Reinhard	Dipl.-Ing., Hennef Department of Water and Waste Management
-----------------------	--

Content

Editor's Note on the English Translation	3
Foreword	4
Authors	5
List of Figures	8
List of Tables	8
User Notes	9
1 Scope	9
2 Terms	10
2.1 Definitions	10
2.2 Symbols and Abbreviations	11
3 Classification and Definition of the Procedure	16
3.1 Status Quo	16
3.2 Approach of the Standard	17
4 Requirements for Data Material and Parties Involved	18
4.1 Key Success Factors of an Energy Check and an Energy Analysis	18
4.1.1 Key Success Factors of an Energy Check	18
4.1.2 Key Success Factors of an Energy Analysis	18
4.2 Data Volume and Data Quality	19
4.2.1 Determination of the Intake Load	19
4.2.2 Data Volume and Data Quality within the Scope of an Energy Check	19
4.2.3 Data Volume and Data Quality within the Scope of an Energy Analysis	21
4.2.4 Plausibility Check of the Data within the Scope of the Energy Analysis	23
5 Energy Check	24
6 Energy Analysis	31
6.1 General	31
6.2 Assessment of the As-is Status	32
6.3 Preparation of a Consumer Matrix and Energy Balance of the As-is Status	33
6.3.1 Determination of the Power Consumption	33
6.3.2 Heat Demand	35
6.3.3 Power and Heat Production	35
6.3.4 Energy Balance	36
6.4 Determination of Plant-related Ideal Values	36
6.4.1 Preliminary Remark	36
6.4.2 Review of the Existing Plant	36
6.4.3 Calculation of the Plant-related characteristic Values under Average Load Conditions ...	37
6.4.4 Calculation of the Plant-related Ideal Values	37
6.4.5 Advice for the Consideration of Part Load Performance	38
6.5 Evaluation of the As-is Status and the Identification of Measures	38

6.5.1	Evaluation of the As-is Status.....	38
6.5.2	Identification of Measures	39
6.6	Determination of the Savings Potential and of the Economic Efficiency of the Measures	39
6.6.1	Determination of the Energetic Savings Potential	39
6.6.2	Determination of the Economic Efficiency	40
6.7	Formation of a Range of Measures in Order of Priority	40
6.8	Reporting	41
7	Instruments for Monitoring Success.....	42
8	Costs and Environmental Effects	43
8.1	Effects on the Effluent Quality of Wastewater Treatment Plants	43
8.2	Other Environmental Effects	43
8.2.1	Cost Impact	43
Annex A	(informative) Calculation Approaches for Determination of the Plant-related Ideal Value	44
A.1	(informative) Calculation Approaches for Determination of the Plant-related Ideal Value for Power Consumption	45
A.2	(informative) Calculation Approaches for Determination of the Plant-related Ideal Value for Heat Demand	49
A.3	(informative) Calculation Approaches for Determination of the Plant-related Ideal Value for Power and Heat Production	50
A.4	(informative) Tabular List of Electric and Thermal Efficiency of a CHP	51
A.5	(informative) Electrical Efficiencies of Three-phase-motors	52
A.6	(informative) Typical Efficiency Curve of an Asynchronous Machine at Part-load	53
A.7	(informative) Target Values for the Average Overall Efficiency and Specific Power Consumption of Pumps on Wastewater Treatment Plants.....	54
A.8	(informative) Table of Standards for Compressed Air and Surface Aeration Systems According to Guideline DWA-M 229-1:2013.....	55
Annex B	(informative) Statistic Evaluation of the Energy Analysis Sponsored by the State of North Rhine-Westphalia Concerning the Inhabitant-specific Power Consumption According to Procedural Groups of Wastewater Treatment....	56
Annex C	(informative) Example of a Consumer Matrix (Excerpt)	57
Annex D	(informative) Exemplary Comparison of Plant-related Ideal Values in Relation to the As-is Status	58
Annex E	(informative) Comparison of the Energy Demand and the Fulfilment of Demand, Separated According to Power and Heat (Energy Balance).....	59
Annex F	(informative) Energy Flow Diagram	60
Annex G	(informative) Example for an Energy Performance Certificate after Implementation of Individual Measure Packages (Exemplary Figures)	60
	Sources and Bibliography	61

List of Figures

Figures 1 and 2: Specific total power consumption depending on the cleaning process	26
Figure 3: Specific power consumption of the aeration e_{aer} of a wastewater treatment plant.....	27
Figure 4: Specific digester gas production e_{DG} in relation to the total number of inhabitants and population equivalents connected.....	28
Figure 5: Specific digester gas production Y_{DG} in relation to fed organic dry mass.....	29
Figure 6: Rate of digester gas conversion into electricity N_{DG}	29
Figure 7: Degree of self-supply of electricity SSE_{el}	30
Figure 8: Specific external heat consumption e_{ext}	31
Figure 9: Specific power consumption of wastewater pumping stations e_{PStat}	31
Figure 10: Process description of an energy analysis.....	33

List of Tables

Table 1: Symbols.....	11
Table 2: Abbreviations	14
Table 3: Indices used	15
Table 4: Characteristic values of the energy check	24
Table D.1: Energy analysis according to Standard DWA-A 216E and "Energiehandbuch NRW"	58
Table E.1: Energy balance for power.....	59
Table E.2: Heat balance of the wastewater treatment plant.....	59

User Notes

This Standard has been produced by a group of technical, scientific and economic experts, working in an honorary capacity and applying the rules and procedures of the DWA and the Standard DWA-A 400. Based on judicial precedent, there exists an actual presumption that this document is textually and technically correct and also generally recognised.

Any party is free to make use of this Standard. However, the application of its contents may also be made an obligation under the terms of legal or administrative regulations, or of a contract, or for some other legal reason.

This Standard is an important, but not the sole, source of information for solutions to technical problems. Applying information given here does not relieve the user of responsibility for his own actions or for correctly applying this information in specific cases. This holds true in particular when it comes to respecting the margins laid down in this Standard.

1 Scope

This Standard provides a practice-based working instrument related to process engineering and energy optimisation of wastewater systems for planners, operators and competent authorities.

The area of application of this Standard covers facilities for wastewater treatment and wastewater discharge.

The energetic assessment of pumping stations on the basis of the approaches introduced in this Standard in the field of wastewater collection should be made in the same way as for pumping stations in wastewater treatment plants. Currently, there is no sufficient systematically collected data on operational experience in the field of rainwater- and combined sewer treatment plants (e.g. retention soil filter etc.). Same applies for compressed air flow, pneumatic conveyance as well as vacuum-drainage and pressure drainage.

Basically this system is also transferable to wastewater treatment plants in the industrial sector. The difference between industrial and municipal wastewater treatment plants is found in the former's particular load situation and the their specifically optimised cleaning processes.

The approach to refer the energy consumption to the connected total number of inhabitants and population equivalents chosen in this Standard is similar to the applied system of indicators used in benchmarking (see AGIS 2002). According to this, the collected data can easily be used in benchmarking. In addition to the comparison of key figures therein, additional technical calculations are provided within the energy analysis which are helpful with regard to the development and the assessment of measures in particular. In this sense, the energy analysis constitutes a supplement for the development of action alternatives.

PREVIEW

Wastewater treatment is one of the largest energy consumers in a municipality. The results of energy analysis conducted show great potential for increasing energy efficiency of wastewater systems. In view of the complex process sequences in wastewater disposal, a systematic approach and extensive expertise is necessary with regard to the energy optimisation of wastewater systems. There is no standard nationwide methodology to evaluate the energy efficiency of wastewater systems to date.

The present Standard introduces the energy check and energy analysis as instruments for energy optimisation of wastewater systems and formulates requirements for their execution.

The scope of application of this Standard covers wastewater treatment plants and wastewater collecting. Analogue to pumping stations in wastewater treatment plants, pumping stations in the field of wastewater collecting are open to an energetic assessment by means of the presented approaches. At present no adequate systematically collected operational experience has been gained in the field of rainwater and combined wastewater treatment plants (e.g. retention soil filters etc.). The same applies for compressed air flow, pneumatic conveyance, vacuum drainage and pressure main networks.

This Standard provides planners, operators and competent authorities with a practice-oriented and scientifically sound working aid for the procedural and energetic optimisation of wastewater systems and a consistent methodology.

PREVIEW

ISBN: 978-3-88721-570-5 (Print)
978-3-88721-571-2 (E-Book)

German Association for Water, Wastewater and Waste
Deutsche Vereinigung für Wasserwirtschaft, Abwasser und Abfall e. V. (DWA)
Theodor-Heuss-Allee 17 · 53773 Hennef · Germany
Phone +49 2242 872-333 · Fax: +49 2242 872-100
info@dwa.de · en.dwa.de