



DWA Set of Rules

Standard DWA-A 262E

Principles for Dimensioning, Construction and Operation of Wastewater Treatment Plants with Planted and Unplanted Filters for Treatment of Domestic and Municipal Wastewater

November 2017

Grundsätze für Bemessung, Bau und Betrieb von Kläranlagen mit
bepflanzten und unbepflanzten Filtern zur Reinigung häuslichen und
kommunalen Abwassers
November 2017



VORSCHAU

DWA Set of Rules

Standard DWA-A 262E

Principles for Dimensioning, Construction and Operation of Wastewater Treatment Plants with Planted and Unplanted Filters for Treatment of Domestic and Municipal Wastewater

November 2017

Grundsätze für Bemessung, Bau und Betrieb von Kläranlagen mit
bepflanzten und unbepflanzten Filtern zur Reinigung häuslichen
und kommunalen Abwassers
November 2017

VORSCHAU

The German Association for Water, Wastewater and Waste (DWA) is strongly committed to the development of secure and sustainable water and waste management. As a politically and economically independent organisation it is professionally active in the field of water management, wastewater, waste and soil protection.

In Europe DWA is the association with the largest number of members within this field. Therefore it takes on a unique position in connection with professional competence regarding standardisation, professional training and information. The approximately 14,000 members represent specialists and executives from municipalities, universities, engineering offices, authorities and companies.

Imprint

Publisher and marketing:

German Association for
Water, Wastewater and Waste (DWA)
Theodor-Heuss-Allee 17
53773 Hennef, Germany
Tel.: +49 2242 872-333
Fax: +49 2242 872-100
E-Mail: info@dwa.de
Internet: www.dwa.de

Translation:

Dr. Jaime Nivala, Dipl.-Ing. Katy Bernhard,
Dr. Daniel Meyer

Print:

XYXYXYXYXYXYXYXYXYXY

ISBN:

978-3-88721-641-2 (Print)
978-3-88721-642-9 (E-Book)

Printed on 100 % recycled paper

© Deutsche Vereinigung für Wasserwirtschaft, Abwasser und Abfall e. V. (DWA), Hennef 2018
German Association for Water, Wastewater and Waste

All rights, in particular those of translation into other languages, are reserved. No part of this Standard may be reproduced in any form – by photocopy, digitalisation or any other process – or transferred into a language usable in machines, in particular data processing machines, without the written approval of the publisher.

Foreword

This document is a revision of the Standard DWA-A 262 (March 2006). This revision is based on a variety of findings gained in recent years from experience with planted and unplanted filters in Germany and across Europe. Prior to publication of the “yellow print” (a draft released for public review in April 2016), the proposed changes to the Standard were discussed with technical experts in January 2014.

Wastewater treatment with planted and unplanted filters is characterized by a simple structural design, a simple mode of operation, a low production of biomass and secondary sludge, a low use of external energy, and a high treatment efficiency, even for treatment systems with a small number of sewer connections. Horizontal flow filters are described in this Standard only as a downstream (tertiary) treatment stage, no longer as a main (secondary) biological treatment stage, since there is not sufficient knowledge in comparison to vertical flow filters. However, this does not exclude their application. As long as the water management requirements and effluent parameters are met and proper operation is ensured, existing systems can continue to be operated.

Changes

Compared to the Standard DWA-A 262 (March 2006), the following changes have been made:

- a) modification to the title of the Standard;
- b) adaptation to European standards and changes that have occurred in laws and regulations in the meantime;
- c) consideration of recent findings on primary treatment with multicompartment septic tanks;
- d) newly added: treatment systems with raw wastewater filters for combined sewer networks and for separated sewer networks;
- e) newly added: treatment systems with lava sand filters for combined sewer networks and for separated sewer networks;
- f) newly added: two-stage process with vertical flow filters;
- g) newly added: actively aerated filters;
- h) newly added: two-layer filter trenches;
- i) newly added: seasonally loaded treatment systems;
- j) newly added: systems for greywater treatment.

The Standard is aimed at wastewater treatment plant planners and operators as well as specialist authorities.

This Standard on small wastewater treatment systems (< 50 P) deals with the requirements resulting from reasons of water protection that are not covered by unified European standards, both for CE-marked and non CE-marked wastewater treatment systems as well as non-mass-produced small wastewater treatment systems.

The design principles presented here apply to Central European climatic conditions with warm summers and cold winters without permafrost. In other climatic conditions, changes in the design are possible, or even necessary. Regions with permafrost are fundamentally unsuitable for filters.

DWA-A 262E

In order to provide a clear and easy-to-read text, this document uses the feminine form (in German) in a generalized way for personal occupational and functional titles. However, all information applies equally to all genders.

Previous Versions

Standard DWA-A 262 (March 2006)

Standard ATV-A 262 (July 1998)

Technical Report ATV-H 262 (August 1989)

VORSCHAU

Authors

This Standard has been developed in cooperation with the DWA Technical Committee KA-10 "Sanitation in rural areas" and the DWA Working Group KA-10.1 "Wastewater treatment in planted filters".

Members of the DWA Technical Committee KA-10 include:

ALBOLD, Andrea	Dipl.-Ing., Lübeck
DORGELOH, Elmar	Dr.-Ing., Aachen
ENGLMANN, Erich	Dipl.-Ing., Munich
FLOHR, Johann	Dipl.-Ing., Pforzheim
HEISE, Bodo	Dipl.-Ing., Neubrandenburg
KÜHN, Volker	Dr.-Ing., Dresden
LONDONG, Jörg	Prof. Dr.-Ing., Weimar
MAUS, Heinz †	Dipl.-Ing., Arnsberg
NOWAK, Jens	Prof. Dr.-Ing., Potsdam/Berlin (Chairman)
OTTO, Ulrich	Dr.-Ing., Viersen

has contributed, as a guest:

HILMER, Ralf	Dipl.-Ing., Hildesheim
--------------	------------------------

Members of the DWA Working Group KA-10.1 include:

VAN AFFERDEN, Manfred	Dr. rer. nat., Leipzig
ALBOLD, Andrea	Dipl.-Ing., Lübeck
BERNHARD, Katy	Dipl.-Ing., Leipzig
FEHR, Günter	Dr.-Ing., Hannover
GALANDER, Christine	Dipl.-Biol., Berlin
HASSELBACH, Ralf	Dr.-Ing., Saarbrücken
HEISE, Bodo	Dipl.-Ing., Neubrandenburg
KÜHN, Volker	Dr.-Ing., Dresden
LANGERGRABER, Günter	Dr.-Ing., Vienna
NIVALA, Jaime	Dr.-Ing., Leipzig
NOWAK, Jens	Prof. Dr.-Ing., Potsdam/Berlin (Speaker)
RUSTIGE, Heribert	Dipl.-Ing., Berlin
STOCKBAUER, Martina	Dipl.-Ing., Augsburg

Responsible in the DWA Head Office:

WILHELM, Christian	Dr. -Ing., Hennes Department of Water and Waste Management
--------------------	---

Content

Foreword	3
Authors	5
List of Figures	8
List of Tables	9
User Notes	10
1 Scope	10
2 References	11
3 Terms and Definitions	12
3.1 Definitions	12
3.2 Symbols and Abbreviations	14
4 Dimensioning	19
4.1 Principles of Design	19
4.1.1 Small Wastewater Treatment Systems	19
4.1.2 Municipal Wastewater Treatment Plants	19
4.1.3 Greywater Treatment Plants	21
4.2 Dimensioning of Pretreatment	21
4.2.1 General	21
4.2.2 Multicompartment Septic Tank	21
4.2.3 Rotting Tank	21
4.2.4 Settling Ponds	22
4.2.5 Imhoff Tank	22
4.2.6 Raw Wastewater Filter	23
4.2.7 Aerated Settling Pond	25
4.3 Filter Dimensioning	25
4.3.1 Vertical Filters as the Main Biological Treatment Step for Small Wastewater Treatment Systems from 4 P	25
4.3.1.1 Preliminary Remarks	25
4.3.1.2 Vertical Filter with Sand 0 mm to 2 mm	25
4.3.1.3 Two-stage Vertical Filter with Fine Gravel 2 mm to 8 mm and Coarse Sand mm to 4 mm	26
4.3.1.4 Vertical Filter with Coarse Sand 0 mm to 4 mm	26
4.3.1.5 Actively Aerated Vertical Filter with Gravel 8 mm to 16 mm	26
4.3.1.6 Two-layer Filter Trench with Fine Gravel 2 mm to 8 mm and Coarse Sand 0 mm to 4 mm	27
4.3.2 Actively Aerated Horizontal Filter with 8 mm to 16 mm Gravel as the Main Biological Treatment Step in Small Wastewater Treatment Systems	27
4.3.3 Vertical Flow Filters as the Main Biological Treatment Step in Municipal Wastewater Treatment Plants	28
4.3.3.1 Preliminary Remarks	28
4.3.3.2 Vertical Filter with Sand 0 mm to 2 mm	28

4.3.3.3	Two-stage Vertical Filters with Fine Gravel 2 mm to 8 mm and Coarse Sand 0 mm to 4 mm	29
4.3.3.4	Vertical Filter with Coarse Sand 0 mm to 4 mm	30
4.3.3.5	Actively Aerated Vertical Filter with Gravel 8 mm to 16 mm	30
4.3.3.6	Vertical Filter with Lava Sand 0 mm to 4 mm	31
4.3.4	Vertical Filters with Sand 0 mm to 2 mm as the Main Biological Treatment Step During Seasonal Operation	32
4.3.5	Greywater Treatment.....	34
4.3.6	Downstream Filters in Combination Plants as an Additional Cleaning or Polishing Step	34
4.3.6.1	Vertical Filter with Sand 0 mm to 2 mm.....	34
4.3.6.2	Horizontal Filter with Coarse Sand 0 mm to 4 mm or Gravel 2 mm to 8 mm	35
4.4	Summary of Dimensioning and Processes	36
4.5	Treatment Systems with Additional Requirements on the Effluent Quality	43
5	Design and Construction	45
5.1	Location	45
5.2	General Requirements for Pretreatment.....	45
5.3	Lining	45
5.4	Filter Construction.....	46
5.4.1	General.....	46
5.4.2	Vertical Flow Filters.....	51
5.4.2.1	Raw Wastewater Filter	51
5.4.2.2	Vertical Filter with Sand 0 mm to 2 mm.....	51
5.4.2.3	Two-stage Vertical Filter with Fine Gravel 2 mm to 8 mm and Coarse Sand 0 m to 4 mm.....	52
5.4.2.4	Vertical Filter with Coarse sand 0 mm to 4 mm.....	53
5.4.2.5	Actively Aerated Vertical Filter with Gravel 8 mm to 16 mm	53
5.4.2.6	Vertical Filter and Overflow Filter with Lava Sand 0 mm to 4 mm	54
5.4.2.7	Two-layer Filter Trench with Fine Gravel 2 mm to 8 mm and Coarse Sand 0 m to 4 mm.....	55
5.4.3	Horizontal Flow Filters	56
5.4.3.1	Horizontal Filter with Coarse Sand 0 mm to 4 mm.....	56
5.4.3.2	Horizontal Filter with Fine Gravel 2 mm to 8 mm.....	57
5.4.3.3	Actively Aerated Horizontal Filter with Gravel 8 mm to 16 mm.....	58
5.5	Inlet and Outlet Construction	59
5.5.1	General.....	59
5.5.2	Inlet and Outlet Structures for Vertical Flow Filters.....	59
5.5.2.1	Preliminary Remarks	59
5.5.2.2	Raw Wastewater Filter	60
5.5.2.3	Vertical Flow Filter with Sand 0 mm to 2 mm	60
5.5.2.4	Two-stage Vertical Filter with Fine Gravel 2 mm to 8 mm and Coarse Sand 0 mm to 4 mm	60
5.5.2.5	Vertical Filter with Coarse Sand 0 mm to 4 mm	60
5.5.2.6	Actively Aerated Vertical Filter with Gravel 8 mm to 16 mm	60
5.5.2.7	Vertical Filter with Lava Sand 0 mm to 4 mm	61

5.5.2.8	Two-layer Filter Trench with Fine Gravel 2 mm to 8 mm and Coarse Sand 0 mm to 4 mm	61
5.5.3	Inlet and Outlet Structures for Horizontal Flow Filters	61
5.6	Planting of Filters	61
5.7	Further Specifications Regarding Construction.....	62
6	Operation	63
6.1	Fundamentals	63
6.2	Function Control	63
6.2.1	General	63
6.2.2	Self-inspection and Maintenance of Small Wastewater Treatment Systems	63
6.2.3	Self-inspection and Maintenance of Municipal Wastewater Treatment Plants	65
6.3	Sludge Removal for Pretreatment Technologies	66
6.3.1	Multicompartment Septic Tanks	66
6.3.2	Settling Ponds.....	66
6.3.3	Imhoff Tanks	67
6.3.4	Raw Wastewater Filter	67
6.3.5	Aerated Settling Ponds.....	67
6.4	Operating Instructions.....	67
7	Costs	68
8	Environmental Impact	68
Sources and References		69

List of Figures

Figure 1:	Settling pond for primary treatment, schematic diagram with important dimensions.....	22
Figure 2:	Imhoff tank, schematic diagram with important dimensions.....	23
Figure 3:	Raw wastewater filter, schematic diagram with important dimensions, systems for separate sewer networks and combined sewer networks	24
Figure 4:	Aerated settling pond, schematic diagram with important dimensions.....	25
Figure 5:	Process diagram of a municipal wastewater treatment plant for a combined sewer network, with an aerated lagoon, two vertical flow filters with lava sand, and an overflow filter with lava sand.....	31
Figure 6:	Vertical filter with sand 0 mm to 2 mm, schematic diagram with important dimensions.....	51
Figure 7:	Vertical filter (1 st stage) with fine gravel 2 mm to 8 mm, schematic diagram with important dimensions.....	52
Figure 8:	Vertical filter (2 nd stage) with coarse sand 0 mm to 4 mm, schematic diagram with important dimensions.....	52
Figure 9:	Vertical filter with coarse sand 0 mm to 4 mm, schematic diagram with important dimensions.....	53
Figure 10:	Actively aerated vertical filter with medium gravel 8 mm to 16 mm, schematic diagram with important dimensions.....	53
Figure 11:	Vertical filter and overflow filter with lava sand 0 mm to 4 mm, schematic diagram with important dimensions	54
Figure 12:	Two-layer filter trench with fine gravel 2 mm to 8 mm and coarse sand 0 mm to 4 mm, schematic diagram with important dimensions	56

Figure 13: Horizontal filter, schematic diagram with important dimensions, independent from type of filter material used	57
Figure 14: Actively aerated horizontal filter with gravel 8 mm to 16 mm, schematic diagram with important dimensions	58

List of Tables

Table 1: Wastewater specific mass loads per population equivalent in g/(P · d)	20
Table 2: Greywater specific mass loads per population equivalent in g/(P · d)	21
Table 3: Requirements for raw wastewater filters for use as primary treatment	23
Table 4: Requirements of vertical filters with sand for use as the main biological treatment step in small wastewater treatment systems.....	25
Table 5: Requirements of two-stage vertical filters with fine gravel and coarse sand for use as the main biological treatment step in small wastewater treatment systems.....	26
Table 6: Requirements of vertical filters with coarse sand for use as the main biological treatment step in small wastewater treatment systems.....	26
Table 7: Requirements of actively aerated vertical filters with gravel for use as the main biological treatment step in small wastewater treatment systems.....	26
Table 8: Requirements of two-layer filter trenches with fine gravel and coarse sand for use as the main biological treatment step in small wastewater treatment systems	27
Table 9: Requirements of actively aerated horizontal filters with gravel for use as the main biological treatment step in small wastewater treatment systems.....	27
Table 10: Requirements of vertical filters with sand for use as the main biological treatment step in municipal wastewater treatment plants	28
Table 11: Requirements of two-stage vertical filters with fine gravel and coarse sand for use as the main biological treatment step in municipal wastewater treatment plants.....	29
Table 12: Requirements of vertical filters with coarse sand for use as the main biological treatment step in municipal wastewater treatment plants	30
Table 13: Requirements of actively aerated vertical filters with gravel for use as the main biological treatment step in municipal wastewater treatment plants	31
Table 14: Requirements of vertical filters with lava sand for use as the main biological treatment step in municipal wastewater treatment plants	32
Table 15: Requirements of vertical flow filters with sand for use as a polishing step.....	34
Table 16: Requirements of horizontal filters with coarse sand or gravel for use as a downstream treatment step.....	35
Table 17: Summary of the most important design parameters for planted and unplanted filters in small wastewater treatment systems	37
Table 18: Summary of the most important design parameters for planted and unplanted filters in municipal wastewater treatment systems	39
Table 19: Selected examples of common combinations of the different treatment steps	41
Table 20: Characteristics of different soil types	47
Table 21: Characteristics of recommended filter materials	49
Table 22: Self-inspection tasks for small wastewater treatment systems, for treatment system operators	63
Table 23: Maintenance requirements of small wastewater treatment systems, for trained operators	64
Table 24: Scope and timing of self-inspection and maintenance checks for municipal wastewater treatment plants	66

User Notes

This Standard has been produced by a group of technical, scientific and economic experts, working in an honorary capacity and applying the rules and procedures of the DWA and the Standard DWA-A 400. Based on judicial precedent, there exists an actual presumption that this document is textually and technically correct and also generally recognised.

Any party is free to make use of this Standard. However, the application of its contents may also be made an obligation under the terms of legal or administrative regulations, or of a contract, or for some other legal reason.

This Standard is an important, but not the sole, source of information for solutions to technical problems. Applying information given here does not relieve the user of responsibility for his own actions or for correctly applying this information in specific cases. This holds true in particular when it comes to respecting the margins laid down in this Standard.

1 Scope

This Standard sets out a common basis for the design, construction, and operation of planted and unplanted filters for biological treatment of municipal wastewater.

The treatment of wastewater that differs significantly in nature from municipal or household wastewater, as well as the treatment of separated partial wastewater streams - with the exception of greywater - fall outside of the scope of this Standard.

The scope of this Standard includes planted and unplanted filters for:

- small wastewater treatment systems treating domestic wastewater with an inflow of up to 50 P;
- wastewater treatment systems serving fewer than 50 P for which extraneous water must be taken into account. By definition, these are not small wastewater treatment systems, because small wastewater treatment plants may not be connected to sewer networks where extraneous water (e.g., rainwater flowing into shaft covers or infiltration of groundwater into the sewer network) is an issue. These systems must be considered as municipal wastewater treatment plants;
- municipal wastewater treatment plants with either separated or combined sewer networks;
- combined wastewater treatment plants providing additional biological treatment or polishing;
- seasonal wastewater treatment plants operated only in summer.

Generally, the treatment plants described herein are able to meet the wastewater treatment requirements according to the Size Class #1, Appendix 1, Part C of the German Wastewater Ordinance ($BOD_5 \leq 40$ mg/l, $COD \leq 150$ mg/l in randomly collected samples; four out of five samples must be within the limit). In addition, vertical flow filters and aerated horizontal flow filters are suitable for further nitrification ($S_{NH_4} \leq 10$ mg/l) at filter effluent water temperatures of at least 12°C.

Design advice for achieving total nitrogen removal is provided. However, long-term phosphorus removal in the filters cannot be expected. For this, a separate treatment step is required (not the subject of this Standard). The removal of hygienically relevant microorganisms by planted and unplanted filters is principally possible, but design specifications cannot be established at this time.

For many years, filters have been used for seasonal wastewater treatment. These include systems in alpine areas (higher than 2,000 meters above sea level) treating greywater as well as domestic wastewater. Beyond that, filters have also been used for treating wastewater generated at seasonal

VORSCHAU

This Standard sets out a common basis for the design, construction, and operation of planted and unplanted filters for biological treatment of municipal wastewater.

Wastewater treatment with planted and unplanted filters is characterized by a simple structural design, a simple mode of operation, a low production of biomass and secondary sludge, a low use of external energy, and a high treatment efficiency, even for treatment systems with a small number of sewer connections. Limiting factors for the use of such processes are the comparatively large area requirements and the resulting costs. Due to the low specific area requirement, in particular vertical filters were realized for this reason. Conventional horizontal flow filters are described in this Standard only as a downstream (tertiary) treatment stage, no longer as a main (secondary) biological treatment stage.

In recent years, a large number of findings have been gained from the use of these procedures in Germany and Europe which were taken into account in the new version of the Standard. Newer test results for primary treatment in multicompartment septic tanks were taken into account and new planted and unplanted filters were added. In addition, plants with raw wastewater filters for processing wastewater from combined sewer networks, a two-stage process with vertical flow filters, artificially aerated planted and unplanted filters, specifications for seasonally loaded treatment systems and systems for greywater treatment are described in detail.

This Standard is aimed at planners and operators of wastewater treatment plants with planted and unplanted filters as well as at specialist authorities.

VORSCHAU

ISBN: 978-3-88721-641-2 (Print)
978-3-88721-642-9 (E- Book)

German Association for Water, Wastewater and Waste
Deutsche Vereinigung für Wasserwirtschaft, Abwasser und Abfall e. V. (DWA)
Theodor-Heuss-Allee 17 · 53773 Hennef · Germany
Phone +49 2242 872-333 · Fax: +49 2242 872-100
info@dwa.de · en.dwa.de